



Ref. Certif. No.

SE-94186

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Circuit-breakers for overcurrent protection for household and similar installations (CBOs)

Name and address of the applicant

Zhejiang Chint Electrics Co., Ltd.
No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, 325603, P.R. China

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Note: When more than one factory, please report on page 2

Same as applicant

Ratings and principal characteristics

See page 2

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

NXB-63

Additional information (if necessary may also be reported on page 2)

-

A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015

As shown in the Test Report Ref. No. which forms part of this Certificate

190300987SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Box 1103
SE-164 22 Kista, Sweden
Int +46 8 750 00 00

Date: 21 May 2019



Signature:

Henrik Wikström

Ratings and principal characteristics

$U_n =$ AC220V/230V/240V (1P, 1P+N, 2P)

$U_n =$ AC380V/400V/415V (2P, 3P, 3P+N, 4P)

$I_n =$ 1, 2, 3, 4, 6, 10, 16, 20, 25, 32, 40, 50, 63A

B-, C-&D-type, $I_{cs} = I_{cn} = 6000A$ (except for 2P)

$I_{cs} = I_{cn} = 6000A$ (2P, AC380V/400V/415V)

$I_{cs} = 7500A$, $I_{cn} = 10000A$ (2P, AC220V/230V/240V)

Date: 21 May 2019

Signature: 