



Ref. Certif. No.

HU-001603

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST  
CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE  
CERTIFICATS D'ESSAIS DES EQUIPEMENTS ELECTRIQUES  
(IECEE) METHODE OC**CB TEST CERTIFICATE****CERTIFICAT D'ESSAI OC**Product  
ProduitElectromechanical contactor for household  
and similar purposesName and address of the applicant  
Nom et adresse du demandeurZhejiang Chint Electrics Co., Ltd.  
No.1, Chint Road, Chint Industrial Zone,  
North Baixiang, Yueqing, Zhejiang Province  
P.R. ChinaName and address of the manufacturer  
Nom et adresse du fabricantZhejiang Chint Electrics Co., Ltd.  
No.1, Chint Road, Chint Industrial Zone,  
North Baixiang, Yueqing, Zhejiang Province  
P.R. ChinaName and address of the factory  
Nom et adresse de l'usineZhejiang Chint Electrics Co., Ltd.  
No.2, Changjiang Road, CHINT Intelligent Electric  
Appliance Industrial Zone, North Baixiang, Yueqing,  
Zhejiang Province, P. R. ChinaNote: When more than one factory, please report on page 2  
Note: Lorsque il y plus d'une usine, veuillez utiliser la 2<sup>ème</sup> pageRatings and principal characteristics  
Valeurs nominales et caractéristiques principalesNumber of poles:  
4P: x=22, 40 or 31; 2P: x=20, 02 or 11;  
NCH8-40/x:  
AC-7a, 230VAC (2P), 40A(7,5kW); 400VAC (4P), 40A(16kW);  
NCH8-63/x:  
AC-7a, 230VAC (2P), 63A(12kW); 400VAC (4P), 63A(26kW);  
Us: AC 24V, 220/230V, 240V, 50/60Hz;  
Ui: 500V; Uimp: 4kV; Ir= 3kA; Iq= 6kA; Ith: 63ATrademark (if any)  
Marque de fabrique (si elle existe)

CHINT

Type of Manufacturer's Testing Laboratories used  
Type de programme du laboratoire d'essais  
constructeur

---

Model / Type Ref.  
Ref. De typeNCH8-40/x (x=22, 40 or 31; x=20, 02 or 11),  
NCH8-63/x (x=22, 40 or 31; x=20, 02 or 11)  
(see Test Report for further details)Additional information (if necessary may also be  
reported on page 2)  
Les informations complémentaires (si nécessaire,  
peuvent être indiqués sur la 2<sup>ème</sup> page


---

A sample of the product was tested and found  
to be in conformity with  
Un échantillon de ce produit a été essayé et a été  
considéré conforme à la

IEC 61095:2009 (ed.2)

As shown in the Test Report Ref. No. which forms part  
of this Certificate  
Comme indiqué dans le Rapport d'essais numéro de  
référence qui constitue partie de ce Certificat

1W150231

This CB Test Certificate is issued by the National Certification Body  
Ce Certificat d'essai OC est établi par l'Organisme National de CertificationTÜV Rheinland InterCert Kft., Division MEEI  
H-1132 Budapest, Váci út 48/A-B TÜVRheinland®  
www.tuv.hu

Date: 2015-09-11

Signature:

Gabor Kassai

