ATTESTATION OF CONFORMITY

Issued to:	Zhejiang Chint Electrics Co., Ltd. No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, 325603 Zhejiang, China
For the product:	Air Circuit-Breaker
Trade name:	CHINT
Type/Model:	NXA32N, NXA32S, NXA32H
Ratings:	Ue: 380 / 400 / 415 Vac, 440 / 525 / 690 Vac In: 3200 A, 2500 A, 2000 A, 1600 A Ui: 1000 V, Uimp: 12 kV, 3P or 4P (N pole with protection) see other technical data on annex pages
Manufactured by:	Zhejiang Chint Electrics Co., Ltd. No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, 325603 Zhejiang, China
Subject:	Type test
Requirements:	EN 60947-2:2017, EN 60947-5-1:2017, IEC 60947-2:2016 and IEC 60947-5-1:2016

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in test reports no. 3313972.50 issued on 2018-12-20, 3312363.51 issued on 2018-01-12 and CQC CB test reports no. 00901-CB2015CQC-067841 issued on 2015-12-28 and no. 00901-CB2015CQC-067841-M1 issued on 2017-06-22 with CQC CB test certificate no. CN36361-A1/M1 issued on 2017-07-14.

This Attestation implies that the examined types/are/in/accordance/with/the/standards/designated under the Low voltage directive (LVD)/2014/35/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Wenzhou, Zhejiang, 02 January 2019

Number:/3313973.01A

DEKRA Testing Services (Zhejiang) Co., Ltd.

Ms J Guo Certification Manager

© Integral publication of this attestation and adjoining reports is allowed The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.

DEKRA Testing Services (Zhejiang) Co., Ltd.

No. 5, Changjiang Road Great Bridge Industrial Park North Baixiang, Wenzhou, Zhejiang, 325603, P. R. China T +86577628680 00 F +86577629198 89 www.dekra-certification.com



ANNEX to ATTESTATION OF CONFORMITY No. 3313973.01A



Ratings

Ratings		
number of poles	:	3P or 4P (N pole with protection)
protected poles		3 or 4
rated operational voltage (Ue)		380 / 400 / 415 Vac, 440 / 525 / 690 Vac
rated insulation voltage (Ui)		1000 V for main circuit
rated mediation vehage (er)	•	415 V for control circuit
		415 V for auxiliary circuit
rated impulse withstand voltage		12 kV for main circuit
(Uimp)	•	6 kV for control circuit
(Omp)		6 kV for auxiliary circuit
rated frequency		50 / 60 Hz
rated frequency	:	
rated current (In)	:	3200 A, 2500 A, 2000 A, 1600 A
conventional thermal current (Ith)		Equal to In
current rating for four-pole circuit-	-	50% In, 100% In adjustable
breakers		
individual pole short-circuit (I_{IT})		12 In at 380 / 400 / 415 / 440 / 525 Vac
suitable for isolation	:	Suitable
selectivity category	:	В
safety distance (screen-circuit	:	Left / Right: 0 mm
breaker)		Up / Down: 0 mm
		Front / Back: 0 mm
reference temperature	:	Independent
method of mounting	:	Fixed or Withdrawable
EMC environment	:	A
tightening torque for terminals	:	50 Nm for M12
line/load terminal	:	Immaterial
connection	:	Copper busbar
		minimum cross-sectional area of conductor (mm ²):
		(100 x 5) mm ² x 2
		maximum cross-sectional area of conductor (mm ²):
		(100 x 10) mm² x 4
electronic trip unit type(s)	:	NKD6 series:
		NKD6-M, NKD6-A, NKD6-P and NKD6-H
		NST1-D series:
		NST1-DM, NST1-DA, NST1-DP and NST1-DH
inverse time delay release		Ir (inverse time delay tripping setting):
	•	For trip units: NKD6-P, NKD6-H
		$(0,4 - 1) \times In$, in steps of 1 A
		For trip units: NST1-DM, NST1-DA, NST1-DP and NST1-DH
		$(0,4 - 1) \times In$, in steps of 2 A
		For trip units: NKD6-M and NKD6-A
		•
		(0,4 / 0,5 / 0,6 / 0,7 / 0,8 / 0,9 / 1) x ln
time setting of the inverse time	:	tr (inverse time delay tripping setting):
delay release	•	1 s / 2 s / 4 s / 8 s / 12 s / 16 s / 20 s / 24 s,
uciay release		with tolerance of $\pm 15\%$ (at 6 lr)
		2 Ir tripping time declared by the manufacturer: when tr = 1 s: 7,65 s - 10,35 s
		when tr = 24 s: 183,6 s - 248,4 s

ANNEX to ATTESTATION OF CONFORMITY No. 3313973.01A



short time delay release	:	Isd (short time delay tripping setting): For trip units: NKD6-P, NKD6-H (2 - 10) x Ir, in steps of 1 A For trip units: NST1-DM, NST1-DA, NST1-DP and NST1-DH (2 - 10) x Ir, in steps of 2 A for Ii < 10 kA, in steps of 0,02 kA for Ii \ge 10 kA For trip units: NKD6-M and NKD6-A (2 / 3 / 4 / 5 / 6 / 8 / 10) x Ir
time setting of the short time delay release	:	tsd (short time delay tripping setting): $I^{2}t$ off: 0,1 s / 0,2 s / 0,3 s / 0,4 s 0,1 s, with tolerance of 60 ms - 140 ms 0,2 s, with tolerance of 160 ms - 240 ms 0,3 s, with tolerance of 255 ms - 345 ms 0,4 s, with tolerance of 340 ms - 460 ms non-tripping duration stated by the manufacturer: 0,1 s: 50 ms 0,2 s: 140 ms 0,3 s: 250 ms 0,4 s: 330 ms
instantaneous release	:	li (instantaneous tripping setting): For trip units: NKD6-P, NKD6-H (2 - 15) x In, in steps of 1 A For trip units: NST1-DM, NST1-DA, NST1-DP and NST1-DH (2 - 15) x In, in steps of 2 A for Ii < 10 kA, in steps of 0,02 kA for Ii \ge 10 kA For trip units: NKD6-M and NKD6-A (2 / 4 / 6 / 8 / 10 / 12 / 15) x In
making current release (MCR) ground fault release	:	26 kA Ig (ground fault release tripping setting): For trip units: NKD6-P and NKD6-H 500 A - 1200 A, in steps of 1 A For trip units: NST1-DM, NST1-DA, NST1-DP and NST1-DH 500 A - 1200 A, in steps of 2 A For trip units: NKD6-M and NKD6-A 500 A / 640 A / 800 A / 960 A / 1040 A / 1120 A / 1200 A
time setting of the ground fault release	:	tg (ground fault release tripping setting): I ² t off: 0,1 s / 0,2 s / 0,3 s / 0,4 s 0,1 s, with tolerance of 60 ms - 140 ms 0,2 s, with tolerance of 160 ms - 240 ms 0,3 s, with tolerance of 255 ms - 345 ms 0,4 s, with tolerance of 340 ms - 460 ms
shunt release	:	220 / 230 / 240 Vac, 380 / 400 / 415 Vac; 110 Vdc, 220 Vdc
under-voltage release closing coil	:	220 / 230 / 240 Vac, 380 / 400 / 415 Vac 220 / 230 / 240 Vac, 380 / 400 / 415 Vac; 110 Vdc, 220 Vdc
stored energy motor	:	220 / 230 / 240 Vac, 380 / 400 / 415 Vac; 110 Vdc, 220 Vdc
auxiliary circuits	:	6NO6NC, 4NO4NC AC-15: 1,3 A at 240 Vac, 0,75 A at 415 Vac; 50 / 60 Hz DC-13: 0,55 A at 110 Vdc, 0,27 A at 220 Vdc Ui: 415 V, Uimp: 6 kV, Ith: 6 A rated conditional short-circuit current: 1 kA SCPD: NT00-6, 6 A



DEKRA

Product rating - NXA32N

rated service short-circuit breaking		80 kA at 380 / 400 / 415 Vac
capacity (Ics)		65 kA at 440 / 525 / 690 Vac
rated ultimate short-circuit breaking		80 kA at 380 / 400 / 415 Vac
capacity (Icu)		65 kA at 440 / 525 / 690 Vac
rated short-time withstand current (Icw)	:	65 kA / 1 s at 380 / 400 / 415 Vac 37 kA / 3 s at 380 / 400 / 415 Vac 65 kA / 1 s at 440 / 525 / 690 Vac

Product rating - NXA32S

capacity (Ics)70 kA at $440 / 525 / 690$ Vacrated ultimate short-circuit breaking capacity (Icu)80 kA at $380 / 400 / 415$ Vacrated short-time withstand current (Icw)80 kA / 1 s at $380 / 400 / 415$ Vac $50 kA / 1 s at 380 / 400 / 415$ Vac $50 kA / 1 s at 380 / 400 / 415$ Vac $50 kA / 1 s at 380 / 400 / 415$ Vac $50 kA / 1 s at 380 / 400 / 415$ Vac $50 kA / 1 s at 380 / 400 / 415$ Vac $50 kA / 1 s at 380 / 400 / 415$ Vac $70 kA at 440 / 525 / 690$ Vac
70 kA / 1 s at 440 / 525 / 690 Vac

Product rating - NXA32H

rated service short-circuit breaking		85 kA at 380 / 400 / 415 Vac
capacity (Ics)		70 kA at 440 / 525 / 690 Vac
rated ultimate short-circuit breaking		100 kA at 380 / 400 / 415 Vac
capacity (Icu)		70 kA at 440 / 525 / 690 Vac
rated short-time withstand current	:	85 kA / 1 s at 380 / 400 / 415 Vac
(Icw)		50 kA / 3 s at 380 / 400 / 415 Vac
		70 kA / 1 s at 440 / 525 / 690 Vac

Additional information

Nomenclature breakdown NXA32N / x, NXA32S / x, NXA32H / x x- represents number of poles, 4 for 4P, blank for 3P