

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Name and address of the applicant

Name and address of the manufacturer

Name and address of the factory

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Trademark (if any)

Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

Customer's Testing Facility (CTF) Stage used

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

Moulded-Case Circuit Breaker

Zhejiang Chint Electrics Co., Ltd.

No. 1, Chint Road, Chint industrial Zone, North Baixiang, Yueqing, Zhejiang

China

Zhejiang Chint Electrics Co., Ltd.

No. 1, Chint Road, Chint industrial Zone, North Baixiang, Yueqing, Zhejiang

China

Additional information on page 2

Zhejiang Chint Electrics Co., Ltd.

No.1318, Binhai No.2 Avenue, Economic and Technical Development Zone, Wenzhou City, Zhejiang

China

Ue: 220 Vac / 230 Vac / 240 Vac / 380 Vac / 400 Vac / 415 Vac. 50 / 60 Hz

Ui: 1000 Vac, Uimp: 12 kV

In: NXM-1250S, NXM-1250H, NXMP-1250S, NXMP-1250H, NXMH-1250S, NXMH-1250H: 1000

A, 1250 A

NXM-1600S, NXM-1600H, NXMP-1600S, NXMP-1600H, NXMH-1600S, NXMH-1600H: 1000 A,

1250 A, 1600 A

3P and 4P (unprotected N pole or protected N pole)

See annex for further ratings

CHINT

NXM-1250H, NXM-1250S, NXM-1600H, NXM-1600S, NXMP-1250H, NXMP-1250S, NXMP-1600H,

NXMP-1600S, NXMH-1250H, NXMH-1250S, NXMH-1600H, NXMH-1600S

Additional information on page 2

IEC 60947-2:2016

3312001.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V. Meander 1051, NL-6825 MJ Arnhem, Netherlands

Date: 2018-03-30



Signature: H.L. Schendstok





ANNEX TO CB TEST CERTIFICATE NL-51144

page 1 of 3

Ratings:

number of poles 3P and 4P (unprotected N pole or protected N pole)

protected pole 3 or 4

rated operational voltage (Ue) 220 Vac / 230 Vac / 240 Vac / 380 Vac / 400 Vac / 415 Vac

rated insulation voltage (Ui) 1000 Vac rated impulse withstand voltage 12 kV

(Uimp)

rated operational current (le) : Equal to In conventional thermal current (Ith) Equal to In current rating for four-pole circuit-Equal to In

breakers

rated frequency 50 / 60 Hz reference temperature 40 °C or 55 °C suitable for isolation Suitable

selectivity category

safety distance (screen-circuit Front / Back: 0 mm, Left / Right: 100 mm, breaker)

Up / Down: 100 mm Magnetic type, adjustable,

instantaneous release 2 poles in series: li: (7, 8, 9, 10) x ln

single pole: 1,2 x li Fixed

time setting of the instantaneous

release

inverse time delay release Thermal type, adjustable, Ir: (0,7, 0,8, 0,9, 1,0) x In

time setting of the inverse time Fixed, trip time at 2 ln: $3 \text{ min} \le t \le 30 \text{ min}$

delay release

method of mounting Fixed A and B **EMC** environment 19,2 kA at 415 Vac

individual pole short-circuit breaking

capacity (lit)

rated tightening torque for terminals

30 Nm line/load terminal Marked connection Copper bar

rating - NXM-1600H

1000 A, 1250 A, 1600 A rated current (In)

rated service short-circuit breaking 75 kA at 220 Vac / 230 Vac / 240 Vac, 50 kA at 380 Vac / 400 Vac / 415 Vac capacity (Ics)

rated ultimate short-circuit breaking 100 kA at 220 Vac / 230 Vac / 240 Vac 70 kA at 380 Vac / 400 Vac / 415 Vac capacity (Icu)

rating - NXM-1250H

rated current (In) 1000 A, 1250 A

rated service short-circuit breaking 75 kA at 220 Vac / 230 Vac / 240 Vac, 50 kA at 380 Vac / 400 Vac / 415 Vac

capacity (Ics)

100 kA at 220 Vac / 230 Vac / 240 Vac rated ultimate short-circuit breaking capacity (Icu) 70 kA at 380 Vac / 400 Vac / 415 Vac



ANNEX TO CB TEST CERTIFICATE NL-51144

page 2 of 3

rating – NXM-1600S

rated current (In)

rated service short-circuit breaking

capacity (Ics)

rated ultimate short-circuit breaking

capacity (Icu)

rating - NXM-1250S

rated current (In)

rated service short-circuit breaking

capacity (Ics)

rated ultimate short-circuit breaking

capacity (Icu)

rating - NXMP-1600H

rated current (In)

rated service short-circuit breaking

capacity (Ics)

rated ultimate short-circuit breaking

capacity (Icu)

rating - NXMP-1250H

rated current (In)

rated service short-circuit breaking

capacity (Ics)

rated ultimate short-circuit breaking

capacity (Icu)

rating - NXMP-1600S

rated current (In)

rated service short-circuit breaking

capacity (Ics)

rated ultimate short-circuit breaking

capacity (Icu)

rating - NXMP-1250S

rated current (In)

rated service short-circuit breaking

capacity (Ics)

rated ultimate short-circuit breaking

capacity (Icu)

rating – NXMH-1600H

rated current (In)

rated service short-circuit breaking

capacity (Ics)

rated ultimate short-circuit breaking

capacity (Icu)

1000 A, 1250 A, 1600 A

50 kA at 220 Vac / 230 Vac / 240 Vac,

36 kA at 380 Vac / 400 Vac / 415 Vac

75 kA at 220 Vac / 230 Vac / 240 Vac

50 kA at 380 Vac / 400 Vac / 415 Vac

1000 A, 1250 A

50 kA at 220 Vac / 230 Vac / 240 Vac.

36 kA at 380 Vac / 400 Vac / 415 Vac

75 kA at 220 Vac / 230 Vac / 240 Vac

50 kA at 380 Vac / 400 Vac / 415 Vac

1000 A, 1250 A, 1600 A

75 kA at 220 Vac / 230 Vac / 240 Vac,

50 kA at 380 Vac / 400 Vac / 415 Vac

100 kA at 220 Vac / 230 Vac / 240 Vac

70 kA at 380 Vac / 400 Vac / 415 Vac

1000 A, 1250 A

75 kA at 220 Vac / 230 Vac / 240 Vac,

50 kA at 380 Vac / 400 Vac / 415 Vac

100 kA at 220 Vac / 230 Vac / 240 Vac

70 kA at 380 Vac / 400 Vac / 415 Vac

1000 A, 1250 A, 1600 A

FO kA at 220 Naa / 220 Na

50 kA at 220 Vac / 230 Vac / 240 Vac,

36 kA at 380 Vac / 400 Vac / 415 Vac 75 kA at 220 Vac / 230 Vac / 240 Vac

50 kA at 380 Vac / 400 Vac / 415 Vac

1000 A, 1250 A

50 kA at 220 Vac / 230 Vac / 240 Vac,

36 kA at 380 Vac / 400 Vac / 415 Vac

75 kA at 220 Vac / 230 Vac / 240 Vac

50 kA at 380 Vac / 400 Vac / 415 Vac

1000 A, 1250 A, 1600 A

75 kA at 220 Vac / 230 Vac / 240 Vac,

50 kA at 380 Vac / 400 Vac / 415 Vac

100 kA at 220 Vac / 230 Vac / 240 Vac

70 kA at 380 Vac / 400 Vac / 415 Vac



ANNEX TO CB TEST CERTIFICATE NL-51144

page 3 of 3

rating - NXMH-1250H

rated current (In) 1000 A, 1250 A

rated service short-circuit breaking 75 kA at 220 Vac / 230 Vac / 240 Vac,

capacity (Ics) 50 kA at 380 Vac / 400 Vac / 415 Vac rated ultimate short-circuit breaking : 100 kA at 220 Vac / 230 Vac / 240 Vac

capacity (Icu) 70 kA at 380 Vac / 400 Vac / 415 Vac

rating – NXMH-1600S

rated current (In) 1000 A, 1250 A, 1600 A

rated service short-circuit breaking 50 kA at 220 Vac / 230 Vac / 240 Vac,

capacity (Ics) 36 kA at 380 Vac / 400 Vac / 415 Vac rated ultimate short-circuit breaking : 75 kA at 220 Vac / 230 Vac / 240 Vac

capacity (Icu) 50 kA at 380 Vac / 400 Vac / 415 Vac

rating - NXMH-1250S

rated current (In) 1000 A, 1250 A

rated service short-circuit breaking 50 kA at 220 Vac / 230 Vac / 240 Vac, capacity (Ics) 36 kA at 380 Vac / 400 Vac / 415 Vac

rated ultimate short-circuit breaking : 75 kA at 220 Vac / 230 Vac / 240 Vac

capacity (Icu) 50 kA at 380 Vac / 400 Vac / 415 Vac

additional information

Nomenclature breakdown:

NXM - 1600 H / 4 300 T C

a b c d e f

a = Model name: 'NXM', 'NXMP', 'NXMH'

b = Frame size: '1600' or '1250' c = Short-circuit capacity: 'S', 'H'

d = Pole numbers, '4' means 4P MCCBs, '3' means 3P MCCBs

e = 'T' means overload release is adjustable

f = For Neutral pole, 'B' means unprotected N pole, 'C' means protected N pole