

CERTIFICATE

Issued to:
Applicant:
Zhejiang Chint Electrics Co., Ltd.
No. 1, Chint Road,
Chint Industrial Zone,
North Baixiang, Yueqing,
Zhejiang, China

Licensee:
Zhejiang Chint Electrics Co., Ltd.
No. 1, Chint Road,
Chint Industrial Zone,
North Baixiang, Yueqing,
Zhejiang, China

Product : Moulded-Case Circuit Breaker
Trade name(s) : CHINT
Type(s)/model(s) : NXM-400F, NXM-400H, NXM-630F, NXM-630H, NXMH-400F, NXMH-400H, NXMH-630F, NXMH-630H, NXMP-400F, NXMP-400H, NXMP-630F and NXMP-630H

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60947-2:2017
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2032236

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 21 March 2018 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 33-102996

DEKRA Certification B.V.



drs. G.J. Zoetbrood
Managing Director



Kreny Lin
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT
Product data

Product	: Moulded-Case Circuit Breaker
Trade name(s)	: CHINT
Type(s)/model(s)	: NXM-400F, NXM-400H, NXM-630F, NXM-630H, NXMH-400F, NXMH-400H, NXMH-630F, NXMH-630H, NXMP-400F, NXMP-400H, NXMP-630F and NXMP-630H
Number of poles	: 3P and 4P (unprotected N pole or protected N pole)
Protected pole	: 3 or 4
Rated operational voltage (Ue)	: 220 Vac / 230 Vac / 240 Vac / 380 Vac / 400 Vac / 415 Vac
Rated insulation voltage (Ui)	: 1000 Vac
Rated impulse withstand voltage (Uimp)	: 12 kV
Rated operational current (Ie)	: Equal to In
Conventional thermal current (Ith)	: Equal to In
Current rating for four-pole circuit-breakers	: Equal to In
Rated frequency	: 50 / 60 Hz
Reference temperature	: 40 °C or 55 °C
Rated service short-circuit breaking capacity (Ics)	: 75 kA at 220 Vac / 230 Vac / 240 Vac, 50 kA at 380 Vac / 400 Vac / 415 Vac
Suitable for isolation	: Suitable
Selectivity category	: A
Safety distance (screen-circuit breaker)	: Front / Back: 0 mm, Left / Right: 100 mm, Up / Down: 100 mm
Instantaneous release	: Magnetic type, fixed, 2 poles in series: $I_i = 10 I_n$ single pole: $12 I_n$
Time setting of the instantaneous release	: Fixed
Inverse time delay release	: Thermal type, Fixed or adjustable $I_r: (0,7, 0,8, 0,9, 1,0) \times I_n$
Time setting of the inverse time delay release	: Fixed, trip time at $2 I_n: 2 \text{ min} \leq t \leq 16 \text{ min}$
Method of mounting	: Fixed
EMC environment	: A and B
Individual pole short-circuit breaking capacity (Iit)	: 7,56 kA at 415 Vac
7,56 kA at 415 Vac	: 22 Nm
Line/load terminal	: Marked
Connection	: Copper conductor with cable lug

Product data – type NXM-400F

Rated current (In)	: 250 A, 280 A, 315 A, 320 A, 400 A
Rated ultimate short-circuit breaking capacity (Icu)	: 75 kA at 220 Vac / 230 Vac / 240 Vac 50 kA at 380 Vac / 400 Vac / 415 Vac

Product data – type NXM-400H

Rated current (In)	: 250 A, 280 A, 315 A, 320 A, 400 A
Rated ultimate short-circuit breaking capacity (Icu)	: 100 kA at 220 Vac / 230 Vac / 240 Vac 70 kA at 380 Vac / 400 Vac / 415 Vac

Product data – type NXM-630F

Rated current (In)	: 400 A, 500 A, 600 A, 630 A
--------------------	------------------------------

Rated ultimate short-circuit breaking capacity (Icu) : 75 kA at 220 Vac / 230 Vac / 240 Vac
50 kA at 380 Vac / 400 Vac / 415 Vac

Product data – type NXM-630H

Rated current (In) : 400 A, 500 A, 600 A, 630 A
Rated ultimate short-circuit breaking capacity (Icu) : 100 kA at 220 Vac / 230 Vac / 240 Vac
70 kA at 380 Vac / 400 Vac / 415 Vac

Product data – type NXMH-400F

Rated current (In) : 250 A, 280 A, 315 A, 320 A, 400 A
Rated ultimate short-circuit breaking capacity (Icu) : 75 kA at 220 Vac / 230 Vac / 240 Vac
50 kA at 380 Vac / 400 Vac / 415 Vac

Product data – type NXMH-400H

Rated current (In) : 250 A, 280 A, 315 A, 320 A, 400 A
Rated ultimate short-circuit breaking capacity (Icu) : 100 kA at 220 Vac / 230 Vac / 240 Vac
70 kA at 380 Vac / 400 Vac / 415 Vac

Product data – type NXMH-630F

Rated current (In) : 400 A, 500 A, 600 A, 630 A
Rated ultimate short-circuit breaking capacity (Icu) : 75 kA at 220 Vac / 230 Vac / 240 Vac
50 kA at 380 Vac / 400 Vac / 415 Vac

Product data – type NXMH-630H

Rated current (In) : 400 A, 500 A, 600 A, 630 A
Rated ultimate short-circuit breaking capacity (Icu) : 100 kA at 220 Vac / 230 Vac / 240 Vac
70 kA at 380 Vac / 400 Vac / 415 Vac

Product data – type NXMP-400F

Rated current (In) : 250 A, 280 A, 315 A, 320 A, 400 A
Rated ultimate short-circuit breaking capacity (Icu) : 75 kA at 220 Vac / 230 Vac / 240 Vac
50 kA at 380 Vac / 400 Vac / 415 Vac

Product data – type NXMP-400H

Rated current (In) : 250 A, 280 A, 315 A, 320 A, 400 A
Rated ultimate short-circuit breaking capacity (Icu) : 100 kA at 220 Vac / 230 Vac / 240 Vac
70 kA at 380 Vac / 400 Vac / 415 Vac

Product data – type NXMP-630F

Rated current (In) : 400 A, 500 A, 600 A, 630 A
Rated ultimate short-circuit breaking capacity (Icu) : 75 kA at 220 Vac / 230 Vac / 240 Vac
50 kA at 380 Vac / 400 Vac / 415 Vac

Product data – type NXMP-630H

Rated current (In) : 400 A, 500 A, 600 A, 630 A
Rated ultimate short-circuit breaking capacity (Icu) : 100 kA at 220 Vac / 230 Vac / 240 Vac
70 kA at 380 Vac / 400 Vac / 415 Vac

TESTS

Test requirements EN 60947-2:2017

Test result

The test results are laid down in DEKRA test file 331199600.

Additional information

NXM - 400 H / 4 300 T B

a b c d e f

a = Model name: 'NXM', 'NXMP', 'NXMH'

b = Frame size: '400' or '630'

c = Short-circuit capacity: 'F', 'H'

d = Pole numbers, '4' means 4P MCCBs, '3' means 3P MCCBs

e = 'Blank' means overload release is fixed, 'T' means overload release is adjustable

f = For Neutral pole, 'B' means unprotected N pole, 'C' means protected N pole

The referred test report is 3311996.50.

The product also complies with IEC 60947-2:2016.

Conclusion

The examination proved that all requirements were met.

Factory location

Zhejiang Chint Electrics Co., Ltd.

No. 1318, Binhai No. 2 Avenue,

Economic and Technical Development Zone,

Wenzhou, Zhejiang, China