

CERTIFICATE

Issued to:
Applicant:
Zhejiang Chint Electrics Co., Ltd.
No. 1, Chint Road,
Chint Industrial Zone,
North Baixiang, Yueqing,
Zhejiang, China

Licensee:
Zhejiang Chint Electrics Co., Ltd.
No. 1, Chint Road,
Chint Industrial Zone,
North Baixiang, Yueqing,
Zhejiang, China

Product : Moulded-Case Circuit-Breaker
Trade name(s) : CHINT
Type(s)/model(s) : NXMS-1000S, NXMSH-1000S and NXMSP-1000S

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60947-2:2017
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2032236

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 19 June 2018 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 33-103649

DEKRA Certification B.V.



drs. G.J. Zoetbrood
Managing Director



Henk Barends
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: Moulded-Case Circuit-Breaker
Trade name(s)	: CHINT
Type(s)/model(s)	: NXMS-1000S, NXMSH-1000S and NXMSP-1000S
Number of poles	: 3P and 4P (protected N pole)
Protected pole	: 3 or 4
Rated operational voltage (Ue)	: 220/230/240/380/400/415 Vac
Rated insulation voltage (Ui)	: 1000 V
Rated impulse withstand voltage (Uimp)	: 12 kV
Rated current (In)	: 800 A, 1000 A
Conventional thermal current (Ith)	: Equal to In
Current rating for four-pole circuit-breakers	: 0,5 In, 1 In, OFF
Rated frequency	: 50/60 Hz
Rated ultimate short-circuit breaking capacity (Icu)	: 75 kA at 220/230/240 Vac 50 kA at 380/400/415 Vac
Rated service short-circuit breaking capacity (Ics)	: 50 kA at 220/230/240 Vac 36 kA at 380/400/415 Vac
Rated short-time withstand current (Icw)	: 12 kA - 1 s at 220/230/240/380/400/415 Vac
Suitable for isolation	: Suitable
Selectivity category	: B
Safety distance (screen-circuit breaker)	: Front / Back: 0 mm, Left / Right: 100 mm, Up / Down: 100 mm
Instantaneous release	: li (instantaneous tripping setting): (2, 3, 4, 6, 8, 10, 12) x In or OFF
Time setting of the instantaneous release	: Fixed
Inverse time delay release	: Ir (inverse time delay tripping setting): 630, 660, 680, 700, 720, 750, 780, 800 A (In: 800 A) 630, 680, 720, 780, 820, 900, 950, 1000 A (In: 1000 A)
Time setting of the inverse time delay release	: 12 s, 60 s, 100 s, 150 s with tolerance of $\pm 20\%$ (at 2 Ir) Trip time at 2 Ir: Set at 12 s: 12 s $\pm 20\%$ Set at 150 s: 150 s $\pm 20\%$
Short time delay release	: Isd (short time delay tripping setting): (1,5, 2, 3, 4, 5, 6, 8) x Ir or OFF
Time setting of short time delay release	: tsd (short time delay tripping setting): 0,3 s with tolerance of $\pm 0,06$ s Non-tripping duration: 0,24 s
Method of mounting	: Fixed
EMC environment	: A and B
Individual pole short-circuit breaking capacity (lit)	: 9,6 kA at 415 Vac
Rated tightening torque for terminals	: 30 Nm
Line/load terminal	: Marked
Connection	: Copper conductor with cable lug or copper bar

TESTS**Test requirements**

EN 60947-2:2017

Test result

The test results are laid down in DEKRA test file 331200800.

Additional information

Nomenclature breakdown:

NXMS - 1000 S / 4 300

a b c d

a = Model name: 'NXMS', 'NXMSP', 'NXMSH'

b = Frame size: 1000

c = Short-circuit capacity: 'S'

d = Pole numbers, '4' means 4P MCCBs, '3' means 3P MCCBs

The referred test report is 3312008.50.

The product also complies with IEC 60947-2:2016.

Conclusion

The examination proved that all requirements were met.

Factory location

Zhejiang Chint Electrics Co., Ltd.

No. 1318, Binhai No. 2 Avenue,

Economic and Technical Development Zone,

Wenzhou, Zhejiang, China