## **ATTESTATION OF CONFORMITY**

Issued to:	Zhejiang Chint Electrics Co., Ltd. No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang, China
For the product:	Moulded-Case Circuit-Breaker
Trade name:	CHINT
Type/Model:	NXMS-400H, NXMSP-400H, NXMSH-400H, NXMS-400F, NXMSP-400F, NXMSH-400F, NXMS-630H, NXMSP-630H, NXMSH-630H, NXMSH-630H, NXMSP-630F, NXMSP-630F and NXMSH-630F
Ratings:	Ue: 220 Vac / 230 Vac / 240 Vac / 380 Vac / 400 Vac / 415 Vac, 50 / 60 Hz Ui: 1000 V, Uimp: 12 kV See annex for further ratings
Manufactured by:	Zhejiang Chint Electrics Co., Ltd. No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang, China
Subject:	Type test
Requirements:	EN/60947-2:2017, IEC/60947-2:2016

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in test report no 3312007.50 issued on 2018-06-06.

This Attestation implies that the examined types are in accordance with the standards designated under the Low voltage directive (LVD) 2014/35/EU

The examination has been carried out on one single specimen or several specimens of the product. submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.

Wenzhou, Zhejiang, 19 June 2018

Number: 3312007.01A

DEKRA Testing Services (Zhejiang) Co., Ltd.

Ms J Guo Certification Manager)

T F © Integral publication of this attestation and adjoining reports is allowed The CE marking may be affixed on the product if all relevant and effective EC directives are complied with

DEKRA Testing Services (Zhejiang) Co., Ltd.

No. 5, Changjiang Road Great Bridge Industrial Park North Baixiang, Wenzhou, Zhejiang, 325603, P. R. China T +86577628680 00 F +86577629198 89 www.dekra-certification.com

## ANNEX TO ATTESTATION OF CONFORMITY NO. 3312007.01A



Page 1 of 4

Ratings: number of poles protected pole rated operational voltage (Ue) rated insulation voltage (Ui) rated impulse withstand voltage (Uimp) conventional thermal current (Ith)		3P and 4P (protected N pole) 3 or 4 220 Vac / 230 Vac / 240 Vac / 380 Vac / 400 Vac / 415 Vac 1000 V 12 kV Equal to In
current rating for four-pole circuit- breakers rated frequency	:	0,5 In, 1 In, OFF 50 / 60 Hz 75 kA at 220 Vac / 220 Vac / 240 Vac
rated service short-circuit breaking capacity (Ics) rated short-time withstand current (Icw)		75 kA at 220 Vac / 230 Vac / 240 Vac 50 kA at 380 Vac / 400 Vac / 415 Vac 8 kA / 1 s at 220 Vac / 230 Vac / 240 Vac / 380 Vac / 400 Vac / 415 Vac
Individual pole short-circuit breaking capacity (lit) suitable for isolation	:	6,05 kA at 415 Vac Suitable
selectivity category safety distance (screen-circuit breaker)	:	B Front / Back: 0 mm, Left / Right: 100 mm,
instantaneous release		Up / Down: 100 mm li (instantaneous tripping setting): (2, 3, 4, 6, 8, 10, 12) x In or OFF
time setting of the instantaneous release		Fixed
time setting of the inverse time delay release	:	12 s, 60 s, 100 s, 150 s with tolerance of $\pm$ 20% (at 2 lr) Trip time at 2 lr: Set at 12 s: 12 s $\pm$ 20% Set at 150 s: 150 s $\pm$ 20%
short time delay release		Isd (short time delay tripping setting): (1,5, 2, 3, 4, 5, 6, 8) x Ir or OFF
time setting of short time delay release	:	tsd (short time delay tripping setting): 0,3 s with tolerance of $\pm$ 0,06 s Non-tripping duration: 0,24 s
method of mounting EMC environment rated tightening torque for terminals line/load terminal connection		Fixed A and B 22 Nm Marked Copper conductor with cable lug

<b>Product rating - NXMS-400H</b> rated current (In) inverse time delay release rated ultimate short-circuit breaking capacity (Icu)		400 A Ir (inverse time delay tripping setting): 200 A, 225 A, 250 A, 280 A, 300 A, 315 A, 350 A, 380 A, 400 A 100 kA at 220 Vac / 230 Vac / 240 Vac 70 kA at 380 Vac / 400 Vac / 415 Vac
<b>Product rating - NXMSP-400H</b> rated current (In) inverse time delay release rated ultimate short-circuit breaking capacity (Icu)	::	400 A Ir (inverse time delay tripping setting): 200 A, 225 A, 250 A, 280 A, 300 A, 315 A, 350 A, 380 A, 400 A 100 kA at 220 Vac / 230 Vac / 240 Vac 70 kA at 380 Vac / 400 Vac / 415 Vac
<b>Product rating - NXMSH-400H</b> rated current (In) inverse time delay release rated ultimate short-circuit breaking capacity (Icu)	: :	400 A Ir (inverse time delay tripping setting): 200 A, 225 A, 250 A, 280 A, 300 A, 315 A, 350 A, 380 A, 400 A 100 kA at 220 Vac / 230 Vac / 240 Vac 70 kA at 380 Vac / 400 Vac / 415 Vac
<b>Product rating - NXMS-630H</b> rated current (In) inverse time delay release rated ultimate short-circuit breaking capacity (Icu)	: :	630 A Ir (inverse time delay tripping setting): 400 A, 450 A, 480 A, 500 A, 530 A, 560 A, 600 A, 630 A 100 kA at 220 Vac / 230 Vac / 240 Vac 70 kA at 380 Vac / 400 Vac / 415 Vac
<b>Product rating - NXMSP-630H</b> rated current (In) inverse time delay release rated ultimate short-circuit breaking capacity (Icu)	::	630 A Ir (inverse time delay tripping setting): 400 A, 450 A, 480 A, 500 A, 530 A, 560 A, 600 A, 630 A 100 kA at 220 Vac / 230 Vac / 240 Vac 70 kA at 380 Vac / 400 Vac / 415 Vac
<b>Product rating - NXMSH-630H</b> rated current (In) inverse time delay release rated ultimate short-circuit breaking capacity (Icu)	: :	630 A Ir (inverse time delay tripping setting): 400 A, 450 A, 480 A, 500 A, 530 A, 560 A, 600 A, 630 A 100 kA at 220 Vac / 230 Vac / 240 Vac 70 kA at 380 Vac / 400 Vac / 415 Vac

	DEKRA		
ANNEX TO ATTESTATION OF CON Product rating - NXMS-400F	FORMITY NO. 3312007.01A	Page 3 of 4	
rated current (In) inverse time delay release	<ul> <li>: 400 A</li> <li>: Ir (inverse time delay tripping setting): 200 A, 225 A, 250 A, 280 A, 300 A, 315 A, 350 A</li> </ul>	380 A 400 A	
rated ultimate short-circuit breaking capacity (Icu)	<ul> <li>75 kA at 220 Vac / 230 Vac / 240 Vac</li> <li>50 kA at 380 Vac / 400 Vac / 415 Vac</li> </ul>	, 0007, 1007	
Product rating - NXMSP-400F rated current (In)	: 400 A		
inverse time delay release	: Ir (inverse time delay tripping setting): 200 A, 225 A, 250 A, 280 A, 300 A, 315 A, 350 A	, 380 A, 400 A	
rated ultimate short-circuit breaking capacity (Icu)	75 kA at 220 Vac / 230 Vac / 240 Vac 50 kA at 380 Vac / 400 Vac / 415 Vac		
<b>Product rating - NXMSH-400F</b> rated current (In) inverse time delay release	<ul> <li>: 400 A</li> <li>: Ir (inverse time delay tripping setting):</li> <li>200 A, 225 A, 250 A, 280 A, 300 A, 315 A, 350 A</li> </ul>	. 380 A. 400 A	
rated ultimate short-circuit breaking capacity (Icu)	<ul> <li>75 kA at 220 Vac / 230 Vac / 240 Vac</li> <li>50 kA at 380 Vac / 400 Vac / 415 Vac</li> </ul>		
Product rating - NXMS-630F rated current (In)	: 630 A		
inverse time delay release	<ul> <li>Ir (inverse time delay tripping setting):</li> <li>400 A, 450 A, 480 A, 500 A, 530 A, 560 A, 600 A</li> </ul>	, 630 A	
rated ultimate short-circuit breaking capacity (Icu)	<ul> <li>75 kA at 220 Vac / 230 Vac / 240 Vac</li> <li>50 kA at 380 Vac / 400 Vac / 415 Vac</li> </ul>		
Product rating - NXMSP-630F rated current (In) inverse time delay release	: 630 A : Ir (inverse time delay tripping setting):		
rated ultimate short-circuit breaking capacity (Icu)	400 A, 450 A, 480 A, 500 A, 530 A, 560 A, 600 A : 75 kA at 220 Vac / 230 Vac / 240 Vac 50 kA at 380 Vac / 400 Vac / 415 Vac	., 630 A	
<b>Product rating - NXMSH-630F</b> rated current (In) inverse time delay release	: 630 A : Ir (inverse time delay tripping setting):		
rated ultimate short-circuit breaking capacity (Icu)	400 A, 450 A, 480 A, 500 A, 530 A, 560 A, 600 A 75 kA at 220 Vac / 230 Vac / 240 Vac 50 kA at 380 Vac / 400 Vac / 415 Vac	., 630 A	



ANNEX TO ATTESTATION OF CONFORMITY NO. 3312007.01/ Additional information Nomenclature breakdown:

<u>NXMS</u> - <u>630 H</u> / <u>4</u> 300

a bcd

- a = Model name: 'NXMS', 'NXMSP', 'NXMSH'
- b = Frame size: '630', '400'
- c = Short-circuit capacity: 'F', 'H'
- d = Pole numbers, '4' means 4P MCCBs, '3' means 3P MCCBs