## **ATTESTATION OF CONFORMITY**

Issued to:	Zhejiang Chint Electrics Co., Ltd. No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang, China
For the product:	Moulded-Case Circuit-Breaker
Trade name:	CHINT
Type/Model:	NXMS-400S, NXMSP-400S, NXMSH-400S, NXMS-630S, NXMSP-630S and NXMSH-630S
Ratings:	Ue: 220 Vac / 230 Vac / 240 Vac / 380 Vac / 400 Vac / 415 Vac, 50 / 60 Hz Ui: 1000 V, Uimp: 12 kV 3P and 4P (protected N pole) See annex for further ratings
Manufactured by:	Zhejiang Chint Electrics Co., Ltd. No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang, China
Subject:	Type test
Requirements:	EN/60947-2:2017, IEC/60947-2:2016
This Attactation is a	canted on account of an examination by DEKRA, the results of which are laid down

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in test report no 3312006.50 issued on 2018-06-06.

This Attestation implies that the examined types/are/in/accordance/with/the/standards/designated/under/ the Low voltage directive (LVD) 2014/35/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Wenzhou, Zhejiang, 19 June 2018

Number: 3312006.01A/

ſF

DEKRA Testing Services (Zhejiang) Co., Ltd.

Ms J Guo Certification Manager

© Integral publication of this attestation and adjoining reports is allowed The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.

DEKRA Testing Services (Zhejiang) Co., Ltd.

No. 5, Changjiang Road Great Bridge Industrial Park North Baixiang, Wenzhou, Zhejiang, 325603, P. R. China T +86577628680 00 F +86577629198 89 www.dekra-certification.com

		DEKRA		
ANNEX TO ATTESTATION OF CONFORMITY NO. 3312006.01A Page 1 of 2				
Ratings:				
number of poles	:	3P and 4P (protected N pole)		
protected pole		3 or 4		
rated operational voltage (Ue)		220 Vac / 230 Vac / 240 Vac / 380 Vac / 400 Vac / 415 Vac		
rated insulation voltage (Ui)		1000 V 12 kV		
rated impulse withstand voltage (Uimp)				
conventional thermal current (Ith)		Equal to In		
current rating for four-pole circuit-		0,5 ln, 1 ln, OFF		
breakers				
rated frequency		50 / 60 Hz		
rated ultimate short-circuit breaking		75 kA at 220 Vac / 230 Vac / 240 Vac		
capacity (Icu)		50 kA at 380 Vac / 400 Vac / 415 Vac		
rated service short-circuit breaking		50 kA at 220 Vac / 230 Vac / 240 Vac		
capacity (Ics) rated short-time withstand current		36 kA at 380 Vac / 400 Vac / 415 Vac 8 kA / 1 s at 220 Vac / 230 Vac / 240 Vac / 380 Vac / 400 Vac /		
	•	415 Vac		
(Icw) suitable for isolation		Suitable		
selectivity category	÷	B		
safety distance (screen-circuit		Front / Back: 0 mm,		
breaker)		Left / Right: 100 mm,		
		Up / Down: 100 mm		
instantaneous release		li (instantaneous tripping setting):		
		(2, 3, 4, 6, 8, 10, 12) x In or OFF		
time setting of the instantaneous		Fixed		
release time setting of the inverse time		12 s, 60 s, 100 s, 150 s with tolerance of ± 20% (at 2 lr)		
delay release		Trip time at 2 Ir:		
		Set at 12 s: 12 s ± 20%		
		Set at 150 s: 150 s ± 20%		
short time delay release	:	Isd (short time delay tripping setting):		
		(1,5, 2, 3, 4, 5, 6, 8) x lr or OFF		
time setting of short time delay		tsd (short time delay tripping setting):		
release		$0,3$ s with tolerance of $\pm 0,06$ s		
method of mounting		Non-tripping duration: 0,24 s Fixed		
EMC environment	÷	A and B		
Individual pole short-circuit	÷	6,048 kA at 415 Vac		
breaking capacity (lit)				
rated tightening torque for terminals		22 Nm		
line/load terminal		Marked		
connection	•	Copper conductor with cable lug		

## ANNEX TO ATTESTATION OF CONFORMITY NO. 3312006.01A

DEKRA

Product rating - NXMS-400Srated current (In)inverse time delay release	400 A Ir (inverse time delay tripping setting): 200 A, 225 A, 250 A, 280 A, 300 A, 315 A, 350 A, 380 A, 400 A
Product rating - NXMSP-400Srated current (In)inverse time delay release:	400 A Ir (inverse time delay tripping setting): 200 A, 225 A, 250 A, 280 A, 300 A, 315 A, 350 A, 380 A, 400 A
Product rating - NXMSH-400Srated current (In)inverse time delay release	400 A Ir (inverse time delay tripping setting): 200 A, 225 A, 250 A, 280 A, 300 A, 315 A, 350 A, 380 A, 400 A
Product rating - NXMS-630Srated current (In)inverse time delay release	630 A Ir (inverse time delay tripping setting): 400 A, 450 A, 480 A, 500 A, 530 A, 560 A, 600 A, 630 A
Product rating - NXMSP-630Srated current (In)inverse time delay release	630 A Ir (inverse time delay tripping setting): 400 A, 450 A, 480 A, 500 A, 530 A, 560 A, 600 A, 630 A
Product rating - NXMSH-630Srated current (In)inverse time delay release	630 A Ir (inverse time delay tripping setting): 400 A, 450 A, 480 A, 500 A, 530 A, 560 A, 600 A, 630 A

## Additional information

Nomenclature breakdown: <u>NXMS</u> - <u>630</u> <u>S</u> / <u>4</u> 300 <u>a</u> <u>b</u> <u>c</u> <u>d</u> a = Model name: 'NXMS', 'NXMSP', 'NXMSH' b = Frame size: '630', '400' c = Short-circuit capacity: 'S' d = Pole numbers, '4' means 4P MCCBs, '3' means 3P MCCBs