



**CHINA QUALITY CERTIFICATION CENTRE**  
**CERTIFICATE OF CONFORMITY**

Certificate No.: CE180305005926

**Product** Motor Protective Circuit-Breaker

**Applicant** NOARK Electrics (Shanghai) Co., Ltd.  
No.3857 Sixian Road, Songjiang District, Shanghai,  
P.R.China

**Type/Model** Ex9S32

**Technical data** See the Appendix


This is to certify that, on the basis of the tests undertaken as per Report No. 00901-CE2018CQC0305-009642, the submitted sample(s) of the above item complies with:

EN 60947-4-1:2010 + A1:2012;EN60947-2:2017  
and fulfills testing requirements of the European Directive:  
2014/35/EU

Valid from: Jul.23,2018

Valid until: Jul.23,2021

President:



CHINA QUALITY CERTIFICATION CENTRE  
Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



**CHINA QUALITY CERTIFICATION CENTRE**  
**CERTIFICATE OF CONFORMITY**

Appendix

Page 1 of 1

Certificate No.: CE180305005926

Ex9S32

Ui: 690V;

Ue: AC400V, AC690V;

In: 0.1-0.16A, 0.16-0.25A, 0.25-0.4A, 0.4-0.63A, 0.63-1A, 1-1.6A, 1.6-2.5A, 2.5-4A, 4-6.3A, 6-10A, 9-14A, 13-18A, 17-23A, 20-25A, 24-32A;

AC400V: Ics=30kA(13-18A - 24-32A), 100kA(0.1-0.16A - 9-14A);

Icu=50kA(13-18A - 24-32A), 100kA(0.1-0.16A - 9-14A);

AC690V: Ics=4kA(2.5-4A - 24-32A), 100kA(0.1-0.16A - 1.6-2.5A);

Icu=6kA(2.5-4A - 24-32A), 100kA(0.1-0.16A - 1.6-2.5A);

Over current release type: Thermal magnetic;

Utilization category: A,AC-3;

Trip Class: 10;

3P

Auxiliary contact and alarm contact:

AX5111, AX5211, AL5111: 1NO1NC

AX5120, AX5220: 2NO

AX5202: 2NC

Ith: 2.5A(AX5111/20), 5A(AX5211/20/02, AL5111)

AX5111/20: AC-15: Ue/Ie: 240V/0.5A, DC-13: Ue/Ie: 60V/0.15A;

AX5211/20/02, AL5111: AC-15: Ue/Ie: 240V/1.5A, 415V/1A,

DC-13: Ue/Ie: 250V/0.2A, 400V/0.1A

President: \_\_\_\_\_



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>