



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE150304004562-A3/H1

Product

AC Contactor

Applicant

NOARK Electrics (Shanghai) Co., Ltd.

No.3857 Sixian Road, Songjiang District, Shanghai,
P.R.China

Type/Model

Ex9C09,Ex9C12,Ex9C18,Ex9C09F,Ex9C12F,Ex9C18F,Ex9
CA09,Ex9CA12,Ex9CA18,Ex9CR09,Ex9CR12,Ex9CR18,E
x9CR09F,Ex9CR12F,Ex9CR18F;

Technical data

See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No.
02401-1911904516, the submitted sample(s) of the above item complies with:

EN 60947-4-1:2010 + A1:2012

and fulfills testing requirements of the European Directive:

2014/35/EU

Valid from: Dec.18,2019

Valid until: Jul.30,2022

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 2

Certificate No.: CE150304004562-A3/H1

Ex9C09,Ex9C12,Ex9C18,Ex9C09F,Ex9C12F,Ex9C18F,Ex9CA09,Ex9CA12,Ex9CA18,
Ex9CR09,Ex9CR12,Ex9CR18,Ex9CR09F,Ex9CR12F,Ex9CR18F;

Ui:690V;

Uimp:6kV;

Ex9C09,Ex9C09F,Ex9CA09,Ex9CR09,Ex9CR09F:

Ith:25A;

AC-1:Ue/Ie:660V/690V/25A;

AC-3:Ue/Ie:220V/230V/240V/9A,380V/400V/415V/9A,660V/690V/6.7A;

AC-4:Ue/Ie:220V/230V/240V/9A,380V/400V/415V/9A,660V/690V/4.9A;

Ex9C12,Ex9C12F,Ex9CA12,Ex9CR12,Ex9CR12F:

Ith:25A;

AC-1:Ue/Ie:660/690V/25A;

AC-3:Ue/Ie:220V/230V/240V/12A,380V/400V/415V/12A,660V/690V/9A;

AC-4:Ue/Ie:220V/230V/240V/12A,380V/400V/415V/12A,660V/690V/4.9A;

Ex9C18,Ex9C18F,Ex9CA18,Ex9CR18,Ex9CR18F:

Ith:32A;

AC-1:Ue/Ie: 660V/690V/32A;

AC-3:Ue/Ie: 220V/230V/240V/18A,380V/400V/415V/18A,660V/690V/10.6A;

AC-4:Ue/Ie: 220V/230V/240V/18A,380V/400V/415V/18A,660V/690V/6.7A;

Us:

Ex9C09~18,Ex9CR09~18,Ex9CA09~18:AC 24V,36V,42V,48V,110V,127V,220V,230V,
240V,380V,400V,415V;50/60Hz;

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Appendix

Page 2 of 2

Certificate No.: CE150304004562-A3/H1

Ex9C09F~18F, Ex9CR09F~18F:100V~250V,48V~130V,24V~60V,50/60Hz/DC;
3P;
IP20;
Auxiliary contact(Body contact):2NO2NC,1NO1NC;
Ith:10A;
AC-15:Ue/Ie:380V/400V/415V/1.9A;
DC-13:Ue/Ie:220V/250V/0.31A;

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>