



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE150304004561-A3/H1

Product

AC contactor

Applicant

NOARK Electrics (Shanghai) Co., Ltd.

No.3857 Sixian Road, Songjiang District, Shanghai,
P.R.China

Type/Model

Ex9C25,Ex9C32,Ex9C38,Ex9C25F,Ex9C32F,Ex9C38F,Ex9
CA25,Ex9CA32,Ex9CA38,Ex9CR25,Ex9CR32,Ex9CR38,E
x9CR25F,Ex9CR32F,Ex9CR38F;

Technical data

See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No.
02401-1911904515, the submitted sample(s) of the above item complies with:

EN 60947-4-1:2010 + A1:2012

and fulfills testing requirements of the European Directive:

2014/35/EU

Valid from: Dec.18,2019

Valid until: Jul.30,2022

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

CE 0010135



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 2

Certificate No.: CE150304004561-A3/H1

Ex9C25,Ex9C32,Ex9C38,Ex9C25F,Ex9C32F,Ex9C38F,Ex9CA25,Ex9CA32,Ex9CA38,
Ex9CR25,Ex9CR32,Ex9CR38,Ex9CR25F,Ex9CR32F,Ex9CR38F;

Uimp:6kV;

Ui:690V;

Ex9C25,Ex9C25F,Ex9CA25,Ex9CR25,Ex9CR25F:

Ith:40A;

AC-1:Ue/Ie:660V/690V/40A;

AC-3:Ue/Ie:220V/230V/240V/25A,380V/400V/415V/25A,660V/690V/17.3A;

AC-4:Ue/Ie:220V/230V/240V/25A,380V/400V/415V/25A,660V/690V/14A;

Ex9C32,Ex9C32F,Ex9CA32,Ex9CR32,Ex9CR32F:

Ith:50A;

AC-1:Ue/Ie:660/690V/50A;

AC-3:Ue/Ie:220V/230V/240V/32A,380V/400V/415V/32A,660V/690V/21.9A;

AC-4:Ue/Ie:220V/230V/240V/32A,380V/400V/415V/32A,660V/690V/17.3A;

Ex9C38,Ex9C38F,Ex9CA38,Ex9CR38,Ex9CR38F:

Ith:50A;

AC-1:Ue/Ie:660V/690V/50A;

AC-3:Ue/Ie:220V/230V/240V/38A,380V/400V/415V/38A,660V/690V/21.9A;

AC-4:Ue/Ie:220V/230V/240V/38A,380V/400V/415V/32A,660V/690V/17.3A;

Us:

Ex9C25~38,Ex9CR25~38,Ex9CA25~38:AC 24V,36V,42V,48V,110V,127V,220V,230V,
240V,380V,400V,415V;50/60Hz;

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Appendix

Page 2 of 2

Certificate No.: CE150304004561-A3/H1

Ex9C25F~38F, Ex9CR25F~38F: 100V~250V, 48V~130V, 24V~60V, 50/60Hz/DC;

IP20;

3P;

Auxiliary Contacts: 2NO2NC, 1NO1NC;

Ith: 10A;

AC-15: 380V/400V/415V, 1.9A;

DC-13: 220V/250V, 0.31A;

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>