

CERTIFICATE OF COMPLIANCE

Certificate Number E516018
Report Reference E516018-20200316
Issue Date 2020-JUNE-05

Issued to: NOARK ELECTRIC USA INC
2188 Pomona Blvd, Pomona CA 91768

**This certificate confirms that
representative samples of**

ADAPTERS, LOW-VOLTAGE AC POWER-SWITCHING
DEVICES

USL, CNL - Adapters, Low-voltage AC Power-switching Devices,
Cat No. CAS12N, followed by 3 or 4, followed by H or V, followed
by 1600, 2500 or 3200

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.


Standard(s) for Safety: ANSI C37.20.1- Low-Voltage AC Power Circuit Breakers Used in
Enclosures – Test Procedures
UL 1066- Low-Voltage AC and DC Power Circuit Breakers Used
in Enclosures
CSA C22.2 No. 31-18- Switchgear Assemblies

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up
Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's
Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

