



Product Service

Attestation of Conformity

No. N8A 075006 0072 Rev. 00

Holder of Certificate: **NOARK Electrics (Shanghai) Co., Ltd.**No.3857 Sixian Road, Songjiang District
201614 Shanghai
PEOPLE'S REPUBLIC OF CHINA**Product:** **Molded case circuit breakers****Model(s):** **Ex9BP****Parameters:**

Rated insulation voltage U_i :	1000V
Rated impulse voltage U_{imp} :	4kV(for 2P appearance), 6kV(for 4P appearance)
Rated current I_n :	10A, 13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A
Rated operational voltage U_e :	DC1000V(4P appearance), DC500V(2P appearance)
Rated service short-circuit breaking capacity I_{cs} :	6kA
Rated ultimate short-circuit Breaking capacity I_{cu} :	6kA
Selectivity category:	A
Type of overcurrent release:	Thermal magnetic

Tested according to: EN 60947-2:2017

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 704102003106-00**Date,** 2020-07-21

(Jie Zhu)

Page 1 of 1

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.