



**CHINA QUALITY CERTIFICATION CENTRE**  
**CERTIFICATE OF CONFORMITY**

**Certificate No.: CE200305006887**

**Product**

Electronic Overload Relay

**Applicant**

NOARK Electrics (Shanghai) Co., Ltd.

No.3857 Sixian Road, Songjiang District, Shanghai, P.R.China

**Type/Model**

Ex9RE40;

**Technical data**

Ui:690V; Uimp:6kV;Ue:690V;Us:  
AC/DC24V,AC110V,AC220V;Ie:0.1-0.5A,0.4-2A,1.8-9A,8-40A;t  
rip class: 5,10,20,30; 3P;IP20(except for the line);Auxiliary  
contact:(body contact):1NO,1NC;Ith:3A;AC-15:AC250V/3A,  
DC-13:DC30V/3A

This is to certify that, on the basis of the tests undertaken as per Report No.  
00901-CE2020CQC0305-011075, the submitted sample(s) of the above item complies  
with:

**EN IEC 60947-4-1:2019**

and fulfills testing requirements of the European Directive:

**2014/35/EU**

**Valid from:** Jul.29,2020

**Valid until:** Jul.29,2023

**President:**

Lu Mei



**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>