



Ref. Certif. No.

CN50879

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

**CB TEST CERTIFICATE**

Product	Electronic Overload Relay
Name and address of the applicant	NOARK Electrics (Shanghai) Co., Ltd. No.3857 Sixian Road, Songjiang District, Shanghai, P.R.China
Name and address of the manufacturer	NOARK Electrics (Shanghai) Co., Ltd. No.3857 Sixian Road, Songjiang District, Shanghai, P.R.China
Name and address of the factory	Zhejiang CHINT Electrics Co., Ltd. No.2, Changjiang Road, CHINT Intelligent Electric Appliance Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, P.R.China
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	Ui:690V; Uimp:6kV;Ue:690V;Us: AC/DC24V,AC110V,AC220V;Ie:0.1-0.5A,0.4-2A,1.8-9A,8-40A;trip class: 5,10,20,30,3P;IP20(except for the line); Auxiliary contact:(body contact)1NO,1NC;lth:3A;AC-15:AC250V/3A, DC-13:DC30V/3A
Trademark (if any)	Noark
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	Ex9RE40;
Additional information (if necessary may also be reported on page 2)	
A sample of the product was tested and found to be in conformity with	IEC 60947-4-1:2018
As shown in the Test Report Ref. No. which forms part of this Certificate	00901-CB2020CQC-091481


This CB Test Certificate is issued by the National Certification Body

**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China  
 Tel: +86-10-83886666 Fax: +86-10-83886282  
 website: <http://www.cqc.com.cn>



Date: Jul.23,2020

Signature:   
Lu Mei

CB 0056466