

IEC**IECEE**

TM

Ref. Certif. No.

CN62358

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product

Contactor For Capacitor Switching

Name and address of the applicant

Zhejiang CHINT Electric Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang CHINT Electric Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory

*Note: When more than one factory, please report on page 2*Zhejiang CHINT Electric Co., Ltd.
No.2, Changjiang Road, CHINT Intelligent Electric Appliance
Industrial Zone, North Baixiang, Yueqing, Zhejiang Province,
P.R.China

Ratings and principal characteristics

See the Appendix

Trademark (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

NXCC-32**, NXCC-43**;

Additional information (if necessary may also be
reported on page 2)A sample of the product was tested and found
to be in conformity with

IEC 60947-4-1:2018

As shown in the Test Report Ref. No. which
forms part of this Certificate

(2023)FQIIDQ-1022

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Oct.13,2023

Signature:

Xie ZhaoXu



NXCC-32**, NXCC-43**

(**=Type and quantity of auxiliary contacts);

Ui:690V;Uimp:6kV;

Ue:AC220V/230V,AC380V/400V,AC660V/690V;

NXCC-32**:Ith:32A;AC-6b:

Ue/Ie:AC220V/230V/30.4A,

AC380V/400V/30.4A,AC660V/690V/30.4A;Qe:AC220V/230V/11.5kvar,AC380V/400V/20kvar,AC660V/690V/34.7kvar;

NXCC-43**:Ith:43A;AC-6b:

Ue/Ie:AC220V/230V/39.4A,

AC380V/400V/39.4A,AC660V/690V/39.4A;Qe:AC220V/230V/15kvar,

AC380V/400V/25.9kvar,

AC660V/690V/45kvar;

Us:AC24V,AC36V,AC42V,AC48V,AC110V,AC120V,AC127V,AC208V,AC220V,AC230V,

AC240V,AC277V,AC380V,AC400V,AC415V,

AC440V,AC460V,AC480V,AC525V,AC600V,

AC660V/50Hz,50/60Hz,60Hz;

3P;IP20(Only applicable to the front side);

Attached auxiliary contacts:

2NO1NC,1NO2NC;Ui:690V;Uimp:6kV;

Ith:10A;AC-15:Ue/Ie:AC220V/230V/2.7A,

AC380V/400V/1.5A;DC-13:Ue/Ie:DC220V/0.3A

Page 1 of 1

Additional information (if necessary)

Date:

Oct.13,2023

Signature:

谢肇煦
Xie ZhaoXu